

GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE ASSISTANT ENGINEER::: PUBLIC HEALTH ENGINEERING
SUB-DIVISION, ITANAGAR ::::::::::: AP

NO.AE/PHESD/ITA/E-15/2024-25/289

Dated 25/03/2025



TO WHOM IT MAY CONCERN

This is to certify that "Vivekananda Residential Public School" at Vivek Vihar, Itanagar, Papum Pare Dist, Arunachal Pradesh has potable drinking water supply provided by PHE & WS Department as per site verified by site Engineer as on 20/03/2025.


Assistant Engineer
PHE & WS Sub Division
Itanagar (A.P.)


Chairman
Vivekananda Res. Public School
Itanagar, A.P


Principal
Vivekananda Res. Public School
Itanagar, A.P

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 20/03/25

It is certified that an inspection team headed by..... Junior Engineer


(Name of Officers with designation) from..... Tamathi Tassam PHED

inspected the..... 20/03/25

(Name & Address of the school) on VR.PS (date of inspection) and on the basis of
Water Test Report (Attached) bearing no..... S.W. 72/108A-7/2024/10 dated..... 7/2024/10 ...
of..... (PHED Lab) certified that the

Vivekananda Residential Public School (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 7th 03/25


Junior Engineer
PHE & WS Sub-Division
Itanagar

Signature with Seal:

Name : Tamathi Tassam

Designation : Junior Engineer

Name & Address of the Office/Department: PHED
Section RRM


To

Principal VR.PS
K.P. Vivekananda, G.P. Itanagar
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies



Chairman
Vivekananda Res. Public School
Itanagar, A.P



Principal
Vivekananda Res. Public School
Itanagar, A.P



GOVERNMENT OF ARUNACHAL PRADESH
STATE WATER QUALITY TESTING LABORATORY
PHE & WS DEPARTMENT,
ITANAGAR

Phone No. 0360-2214057
0360-2292335
Fax No. 0360-2292220

E-Mail id- jjmarunachal@gmail.com

WATER ANALYSIS REPORT

Laboratory reference No. : SWTL/WQR-7/2024/10
Name Applicant : Principal, Vivekananda Res. Public School, Itanagar
Sample source : Supply Water
Date of collection of sample : 31/05/2024
Date of Completion of Test : 03/06/2024

Physical, Chemical and Bacteriological parameters

Sl. No.	Parameter (Unit)	Acceptable Limit (BIS)	Permissible Limit (BIS)	Report
1	Temperature(°C)	-	-	23.9
2	Turbidity (NTU)	1	5	1.93
3	pH	6.5-8.5	No relaxation	7.03
4	Total Dissolved Solid (mg/L)	500	2000	37.1
5	Electrical Conductivity (µS/cm)	-	-	57.07
6	Total Hardness as CaCO ₃ (mg/L)	200	600	16
7	Total Alkalinity (mg/L)	200	600	8
8	Chloride (mg/L)	250	1000	1.0
9	Sulphate (mg/L)	200	400	0.18
10	Fluoride (mg/L)	1.0	1.5	0.02
11	Nitrate (mg/L)	45	No Relaxation	0.24
12	Iron (mg/L)	1.0	No Relaxation	0.53
13	Arsenic (mg/L)	0.01	No Relaxation	BDL*
14	Copper (mg/L)	0.05	1.5	BDL
15	Lead (mg/L)	0.01	No Relaxation	BDL
16	Mercury (mg/L)	0.001	No Relaxation	BDL
17	Zinc (mg/L)	5	15	BDL
18	Cadmium	0.003	No Relaxation	BDL
19	Total Coliform Bacteria (per 100 mL)	0	No Relaxation	0
20	Faecal Coliform Bacteria (per 100 mL)	0	No Relaxation	0

*BDL: Below Detection Limit

Remark: All the tested parameters are within BIS permissible limit.

(Dr. Binod Pokhrel)

Chief Chemist-cum- Consultant State Level WQ
State Water Quality Testing Lab
PHE & WS Deptt. Itanagar.

Chairman
Vivekananda Res. Public School
Itanagar, A.P.

N.B.: This report cannot be used for any legal purpose.

Principal
Vivekananda Res. Public School
Itanagar, A.P.